



ADDENDUM # 2
BID # FY 2021-2022-006
HYDRANT AND VALVE MAINTENANCE, REPAIR, REPLACEMENT AND FLUSHING SERVICES

UPDATED SCOPE

Please ensure you check the City's website for the latest addendum released for this project. Below find the link to the City's website: www.cohb.org\solicitations.

Proposing firms must provide this Addendum # 2 form signed by an authorized officer of the firm to acknowledge receipt of ADDENDUM # 2. The form must be provided with firm's response.

PLEASE NOTE: ORIGINAL SCOPE SECTION 1.2

PAGE # 4:

m. CONTRACTOR shall scrape, wire brush/or sand blast and paint hydrant appropriate color. Paint shall be ANSI Safety Yellow or an approved equal.

PLEASE NOTE: REVISED SCOPE SECTION 1.2

PAGE # 4:

m. CONTRACTOR shall scrape, wire brush/or sand blast and paint hydrant appropriate color. Paint shall be ANSI Safety Yellow or an approved equal. **The city would prefer scrape/wire brush 98% vs Sand blasting.**

PLEASE NOTE: ORIGINAL SCOPE SECTION 1.5

PAGE # 6:

1.5 Contractor "Pass-Through" Charges:

Certain services shall be designated as "Pass-through" charges. For the terms of this contract these services include landscape restoration (excluding irrigation repairs and <100ft² sod), asphalt restoration, concrete restoration, dewatering (well points) services, density testing and extended TTC (>72 hours). Prior to use of cost pass through services, the Contractor shall obtain three (3) separate quotes for each of the activities and present to the CITY's Designee a recommendation of award for each service. If the acceptance of this recommendation is not approved, the CITY's Designee reserves the right to perform all the pass-through activities to avoid the additional pass-through charges with City staff. If this right is exercised by the CITY, the responsibility for such work will be removed from the Contractor.

PLEASE NOTE: REVISED SCOPE SECTION 1.5

PAGE # 6:

1.5 Contractor "Pass-Through" Charges:

Certain services shall be designated as "Pass-through" charges. For the terms of this contract these services include landscape restoration (excluding irrigation repairs and <100ft² sod), asphalt restoration, concrete restoration, dewatering (well points) services, density testing and extended TTC (>72 hours). Prior to use of cost pass through services, the Contractor shall obtain three (3) separate quotes for each of the activities and present to the CITY's Designee a recommendation of award for each service. If the acceptance of this recommendation is not approved, the CITY's Designee reserves the right to perform all the pass-through activities to avoid the additional pass-through charges with City staff. If this right is exercised by the CITY, the responsibility for such work will be removed from the Contractor. **In an event of an emergency or failure, the contractor will install/replace a fire hydrant or valve (whichever is in the operations of the vendor). The city will supply all materials involving a valve or hydrant replacement. Contractor will be responsible for restoring site to its original state.**

PLEASE NOTE RECEIPT OF ADDENDUM # 2 BY SIGNING BELOW AND INCLUDE WITH YOUR FIRM'S SUBMISSION. I ACKNOWLEDGE RECEIPT OF ADDENDUM # 2:

Company	
Name	
Title	
Signature	
Date	

Sincerely,



Andrea Lues, Director, Procurement Department