



ADDENDUM # 6
BID # FY 2021-2022-006
HYDRANT AND VALVE MAINTENANCE, REPAIR, REPLACEMENT AND FLUSHING SERVICES

UPDATED SCOPE

2/23/22

Please ensure you check the City's website for the latest addendum released for this project. Below find the link to the City's website: www.cohb.org\solicitations.

Proposing firms must provide this Addendum # 6 form signed by an authorized officer of the firm to acknowledge receipt of ADDENDUM # 6. The form must be provided with firm's response.

PLEASE NOTE: ORIGINAL SCOPE SECTION 1.2

PAGE # 4:

i. CONTRACTOR shall flow hydrant to maximum rate for 15-minutes, record working pressure and calculate flow rate and gallons flushed. If hydrant fails to flow clear in the initial 15-minute flush notify the CITY's Designee of the discrepancy. Continue to flow hydrant until water clears, checking in 15-minute increments. The use of a calibrated combination pitot gauge and hydrant diffuser is required for all hydrant flushing.

PLEASE NOTE: REVISED SCOPE SECTION 1.2

PAGE # 4:

i. CONTRACTOR shall flow hydrant to maximum rate for 15-minutes, record working pressure and calculate flow rate and gallons flushed. If hydrant fails to flow clear in the initial 15-minute flush notify the CITY's Designee of the discrepancy. Continue to flow hydrant until water clears, checking in 15-minute increments. The use of a calibrated combination pitot gauge and hydrant diffuser is required for all hydrant flushing. **A diffuser will be required while flushing. Also, the flushing will be from 8am-430pm.**

PLEASE NOTE: ORIGINAL SCOPE SECTION 1.2

PAGE # 4:

n. CONTRACTOR shall replace (if defective) hydrant ID tag or install (if not present) hydrant ID tag.

PLEASE NOTE: REVISED SCOPE SECTION 1.2

PAGE # 4:

n. CONTRACTOR shall replace (if defective) hydrant ID tag or install (if not present) hydrant ID tag. **The city will take an accurate record of GIS records in lieu of hydrant tags.**

PLEASE NOTE RECEIPT OF ADDENDUM # 6 BY SIGNING BELOW AND INCLUDE WITH YOUR FIRM'S SUBMISSION. I ACKNOWLEDGE RECEIPT OF ADDENDUM # 6:

Company	
Name	
Title	
Signature	
Date	

Sincerely,



Andrea Lues, Director, Procurement Department