



**ADDENDUM # 9**  
**BID # FY 2021-2022-006**  
**HYDRANT AND VALVE MAINTENANCE, REPAIR, REPLACEMENT AND FLUSHING SERVICES**

**UPDATED SCOPE**  
**3/1/22**

---

Please ensure you check the City's website for the latest addendum released for this project. Below find the link to the City's website: [www.cohb.org/solicitations](http://www.cohb.org/solicitations).

**Proposing firms must provide this Addendum # 9 form signed by an authorized officer of the firm to acknowledge receipt of ADDENDUM # 9. The form must be provided with firm's response.**

**PLEASE NOTE: ORIGINAL SCOPE SECTION 1**

**PAGE # 3:**

The CONTRACTOR is responsible to provide all material and labor required to perform the work as directed by the County Project Coordinator.

**PLEASE NOTE: REVISED SCOPE SECTION 1**

**PAGE # 3:**

The CONTRACTOR is responsible to provide all material and labor required to perform the work, **on a case by case basis**, as directed by the County Project Coordinator.

**On a case-by-case basis hydrants or valves found/confirmed broken upon arrival be replaced under this contract.**

**Any hydrants or valves found broken before the contractor operates it, is the City's responsible. However, the vendor will be responsible for replacement and any restorations.**

**PLEASE NOTE: ORIGINAL SCOPE SECTION 1.1**

**PAGE # 3:**

1.1. Valve Maintenance, Exercising and Replacement:

**PLEASE NOTE: REVISED SCOPE SECTION 1.1**

**PAGE # 3:**

1.1. Valve Maintenance, Exercising and Replacement:

Valve risers are located in all surfaces.

**PLEASE NOTE: ORIGINAL SCOPE SECTION 1.2 PER ADDENDUM # 2**

m. CONTRACTOR shall scrape, wire brush/or sand blast and paint hydrant appropriate color. Paint shall be ANSI Safety Yellow or an approved equal. The city would prefer scrape/wire brush 98% vs Sand blasting.

**PLEASE NOTE: REVISED SCOPE SECTION 1.2**

m. CONTRACTOR shall scrape, wire brush/or sand blast and paint hydrant appropriate color, **only the hydrants that are in need of painting**. Paint shall be ANSI Safety Yellow or an approved equal. The city would prefer scrape/wire brush 98% vs Sand blasting.

**PLEASE NOTE RECEIPT OF ADDENDUM # 9 BY SIGNING BELOW AND INCLUDE WITH YOUR FIRM'S SUBMISSION. I ACKNOWLEDGE RECEIPT OF ADDENDUM # 9:**

Company	
Name	
Title	
Signature	
Date	

Sincerely,

*Andrea Lues*

Andrea Lues, Director, Procurement Department